

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/INSPECTION/2026/053

Dated: 29/05/2026

It is certified that an inspection team headed by DR. R. B. YADAV (Suptd.) with team (Name of Officers with designation) from C.H.C. CHOLAPUR, VARANASI, U.P. PHED inspected the THE LEELA INTERNATIONAL SCHOOL, CHAUBEPUR KHURD, NIYAR ROAD, CHOLAPUR, VARANASI, U.P. (Name & Address of the school) on 29/05/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no C/VNS/MAY26/00178 dated 27/05/2026 of REGIONAL WATER ANALYSIS LABORATORY, GANGA POLLUTION CONTROL UNIT CAMPUS, U.P. JAL NIGAM (RURAL), BHAGWANPUR, LANKA, VARANASI-221005 (PHED Lab) certified that the THE LEELA INTERNATIONAL SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 Year from the date of issue.

To
THE MANAGER
THE LEELA INTERNATIONAL
SCHOOL, CHAUBEPUR KHURD,
NIYAR ROAD, CHOLAPUR,
VARANASI, U.P.
(Name & Address of the
Institution)

Signature with Seal:

Name : DR. R.B.Yadav

Designation : SUPTD.

Name & Address of the Office / Department :
C.H.C. CHOLAPUR, VARANASI, U.P.

अधीक्षक
सामुदायिक स्वास्थ्य केंद्र
चौलापुर-वाराणसी
29.05.26

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Water Analysis Report

Regional Water Analysis Laboratory

Ganga Pollution Control Unit Campus,
U. P. Jal Nigam (Rural), Bhagwanpur, Lanka,
Varanasi-221005

Report No.: C/VNS/MAY26/00178	Date: 27.05.2026	No. of Pages: 1	
Customer Details			
Office Name and Address	The Leela International School, Chaubeypur Khurd, Niyar Road, Cholaapur, Varanasi-221101		
Ref. Letter No. & Date	NA	Date: 25.05.2026	
Basic Details of Sample			
District	Varanasi	Block	Cholapur
Gram Panchayat	Chaubeypur Khurd	Village	Chaubeypur Khurd
Habitation	NA	Location	School Campus, Chaubeypur Khurd
Water Source	RO Water	Sample Code	VNS/MAY26/00178
Quantity of Sample	2000 mL (Normal)	Sampling date	25.05.2026
Sample Received Date	25.05.2026	S. collected by	Mr Ram Prasad Yadav
Sampling Method Used	NA	Sample Depositor	Mr Ram Prasad Yadav
Analysis Start Date	26.05.2026	Analysis Completion date	26.05.2026

Temperature-26.3°C, Humidity- 66%

Test Result					
S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	8.42	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.56	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
3	Total Dissolved Solids, mg/l	232.00	500	2000	IS 3025 (Part 16): 2023 (Gravimetric method)
4	Chloride (as Cl), mg/l	28.03	250	1000	IS 3025 (Part 32): 2019 Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	172.00	200	600	IS 3025 (Part 23): 2023 (Potentiometric and indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	96.00	200	600	IS 3025 (Part 21): 2019 (EDTA method)
7	Calcium (as Ca), mg/l	4.81	75	200	IS 3025 (Part 40): 2019 EDTA Titrimetric method
8	Magnesium (as Mg), mg/l	20.16	30	100	IS 3025 (Part 46): 2023 (Volumetric method)
9	Sulphate (as SO ₄), mg/l	12.67	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method): 2023
10	Nitrate (as NO ₃), mg/l	1.22	45	No relaxation	APHA 24rd Edition -4500- NO ₃ Method B (UV Screening Method): 2023
11	Fluoride (as F), mg/l	0.41	1.0	1.5	APHA 24rd Edition -4500-F Method C (Ion-Selective Electrode Method): 2023
12	Iron (as Fe), mg/l	BDL	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method): 2023

BDL-Below Detection Limit, NA- Not Analysed

- Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.
5. Parameters above Permissible Limit are written in bold.
6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.
7. Sample is not Collected by Lab.
8. Source is not verified by the Lab

ABHAY KUMAR PANDEY
(Report prepared by)

(Report Authorized & Reviewed by)

Laboratory Contact detail:

Email: aroupjn@gmail.com

Mobile No.:8400202287

*****END OF THE ANALYSIS REPORT*****

